



PIPE FITTING SCHEDULE

- 1.No.Vicking Johnson or Similar Coupling.
- 1.No.Pipe not exceeding 2.0m.
- 1.No.All Flanged Gate Valve.
- 1.No.All Flanged Duck foot 90° bend.
- 3.No.Double Flanged Pipe not exceeding 6.0m.
- 1.No.All Flanged 90° bend.
- 2.No.Double Flanged Pipe not exceeding 0.6m.
- 1.No.Flanged Ball Float Valve.
- 1.No.Flanged Adaptor,Maxi type or similar.
- 1.No.Flanged Outlet Pipe Strainer.
- 2.No.Double Flanged Pipe not exceeding 0.6m.
- 1.No.All Flanged 90° bend.
- 2.No.Double Flanged Pipe not exceeding 6.0m.
- 1.No.Double Flanged Pipe not exceeding 2.0m.
- 1.No.All Flanged Duck foot 90° bend.
- 1.No.Flanged Gate Valve.
- 1.No.Flanged Adaptor,Maxi type or similar.
- 1.No.Double Flanged Pipe not exceeding 2.0m.
- 1.No.Vicking Johnson or Similar Coupling.
- 1.No.Flanged Bell Mouth.
- 1.No.Double Flanged Pipe not exceeding 2.8m.
- 1.No.Double Flanged Pipe not exceeding 2.0m.
- 1.No.All Flanged Tee.
- 2.No.Double Flanged Pipe not exceeding 6.0m.
- 1.No.All Flanged Duck foot 90° bend.
- 1.No.All Flanged Pipe with puddle flange n.e 2.0m.
- 1.No.All Flanged 90° bend.
- 1.No.Double Flanged Pipe not exceeding 0.4m.
- 1.No.Flanged Gate Valve.
- 1.No.Flanged Adaptor,Maxi type or similar.

CLIENT



THE REPUBLIC OF UGANDA
MINISTRY OF WATER AND ENVIRONMENT
DIRECTORATE OF WATER DEVELOPMENT

PROJECT

**KAWUMU PRESIDENTIAL MODEL
IRRIGATION SYSTEM AND
FACILITIES**

DETAILED ENGINEERING DESIGN

DRAWING TITLE

**200M³ RESERVOIR TANK
SECTION B-B**

SCALE	AS SHOWN	DRAWING No.	KAW-PRES/IGS/Resr-3.3
SURVEYED		DESIGNED	
DRAWN	N.D	CHECKED	
DATE	MAY 2021	APPROVED	